

CLIO AREA FIRE DEPARTMENT

OPERATING GUIDELINE

TITLE: GENERATORS

REFERENCES: NFPA 1500
DEPARTMENT OF LABOR SAFETY STANDARD - PART 74

GENERATORS, LIKE ALL PORTABLE EQUIPMENT, MUST BE MAINTAINED IN A CONSTANT STATE OF READINESS FOR IMMEDIATE USE. THE SAFETY OF THE MEMBERS OF THE DEPARTMENT AND THE GENERAL PUBLIC, DURING THE TIMES THAT THE GENERATORS ARE IN USE, OR BEING MAINTAINED, IS THE PRIMARY CONSIDERATION.

INSPECTIONS:

Weekly Inspections shall include:
Check fluid levels

INSPECTIONS:

WEEKLY

Inspections shall include;
Check Fluid Levels
Oil
Gasoline
Start and run engine
Check under load by plugging in a light or fan.

ANNUAL

Inspections shall include all parts of the weekly inspection plus;
Change the oil
Clean and/or change the air filter
Clean and/or change the fuel filter